Certificate of Compliance

Dertificate Number 251004 - E216525

Report Reference E216525, October 1st, 2004

ssue Date 2004 October 25



Issued to:

ORTEA SPA

VIA DEL CHIOSI 21

I-20040 CAVENAGO BRIANZA MILANO ITALIA

This is to certify that representative samples of

Systems, Electrical Insulation.

Class 200 (N) insulation system designated ORT-200.

Have been investigated by Underwriters Laboratories Inc. ® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 1446 - Systems of Insulating Materials - General

Additional Information:

Electrical Ratings

System Insulation Maximum Outdoor Maximum Input Designation Class Temperature (Enclosed) Indoor Voltage, V ORT-200 200(N) 200°C hot spot Yes Yes 600

Only those products bearing the UL Recognized Component Mark should be considered as being covered by UL's Recognition and Follow-Un Service.

The UL Recognized Component Mark generally consists of the manufacturer's identification and catalog number, model number or other product designation as specified under "Marking" for the particular Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark: N, may be used in conjuction with the required Recognized Marks. The Recognized Component Mark is required when specified in the UL Directory preceeding the recognitions or under "Markings" for the individual recognitions.

Look for the UL Recognized Component Mark on the product

Roberta Zaffazoni

Roberta Zaffaroni, Engineering Team Leader

Reviewed by: Halele Q. Milch

Adele L. Milch, Engineering Assoc Lead

UL International Italia Srt

UL International Italia Srl

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. For questions in Italy, you may call +39 079 2636600.